

Model/Ref: 368 - 369





Partnership. Without Limits.

www.lauridsenindustri.dk









Size: DN 50 to 300

Ends: Flanged ISO PN16

Min Temperature: - 10°C Max Temperature: + 110°C Max Pressure: 16 Bars

Specifications: Stainless steel disc

All positions

Materials: Cast iron body





SPECIFICATIONS:

- · All positions
- Respect the flow direction indicated by the arrow
- Flanged R.F. ISO PN16
- · Stainless steel disc with spring
- Epoxy blue RAL 003 painting 80 microns thickness


USE:

- Water distribution
- Min Temperature Ts: 10°C
- Max Temperature Ts :+ 110°C
- Max Pressure PN: 16 bars

RANGE:

- Flanged ISO PN16 DN50 to DN300 Ref.369
- Flanged ISO PN16 from DN50 to DN250 with steel strainer basket Ref.368 (Ref.369+367)

MATERIALS:




Item	Designation	Materials
1	Body	Cast iron EN-GJL-250
2	Guide	Cast iron EN-GJL-250
3	Bushing	Bronze
4	Spring	SS 304
5	Gasket	EPDM
6	Disc	SS 304
7	Shaft	SS 416





SIZE REF. 369 (in mm):




Ref.	DN	50	65	80	100	125	150	200	250	300
369	Ø P	56	65	81	105	125	150	200	250	300
	L	100	120	135	165	200	231	288	354	395
	Weight (Kg)	6	9	11	15.5	23.5	34.5	56.5	97.5	145.5





SIZE REF. 368 (in mm):



Ref.	DN	50	65	80	100	125	150	200	250
368	L	100	120	135	165	200	231	288	354
	L1	77	110	125	155	170	220	300	390
	L2	177	230	260	320	370	451	588	744
	ØВ	93	113	128	148	178	200	255	310
	Mesh	6	6	6	6	6	6	6	6
	Weight (Kg)	6.59	9.76	11.83	16.7	24.99	36.3	59.28	101.88





STANDARDS:

- Fabrication according to ISO 9001: 2008
- DIRECTIVE 97/23/CE: Concerned by article 3, § 3
- Flanged R.F. according to EN 1092-2 PN16

ADVICE:Our opinion and our advice are not guaranteed and Lauridsen Industri shall not be liable for the consequences of damages.

The customer must check the right choice of the products with the real service conditions.

INSTALLATION INSTRUCTIONS

GENERAL GUIDELINES:

- Ensure that the check valves to be used are appropriate for the conditions of the installation (type of fluid.pressure and temperature).
- Be sure to have enough valves to be able to isolate the sections of piping as well as the appropriate equipment for maintenance and repair.
- Ensure that the valves to be installed are of correct strenght to be able to support the capacity of their usage.

INSTALLATION INSTRUCTIONS:

- Before installing the check valves, clean and remove any objects from the pipes (in particular bits of sealing and metal) which could obstruct and block the valves.
- Ensure that both connecting pipes either side of the check valve (upstream and downstream) are aligned (if they're not,the valves may not work correctly).
- Make sure that the two sections of the pipe (upstream and downstream) match, the check valve unit
 will not absorb any gaps. Any distortions in the pipes may affect the thightness of the
 connection, the working of the check valve and can even cause a rupture. To be sure, place the kit in
 position to ensure the assembling will work.
- If sections of piping do not have their final support in place, they should be temporarily fixed. This is to avoid unnecessary strain on the check valve.
- If there is a direction changing or if there's another material, it's better to take away the check valve so that it is outside the turbulence area (between 3 and 5 times the ND before and after).
- After a pump please refer to norm NF CR 13932 to install the check valve.

